

**Client:** 



# **Kohler Equipment Maintenance Contract - Twice a Year**

Address:			
Phone: The Air Cooled Gener	Installed: ator(s) Covered in this Conti	Email:	
Model: This service Engine oil char Change air filte Adjust as requi Check automat Check for leaks Change spark p	Serial #: CONSISTS Of: age with oil filter (Twice er (Once a Year) red voltage and frequen ic transfer switch funct s (Twice a Year)	KW Size: e a Year) acy (Twice a Year)	Type: <b>Kohler</b> Fuel: wner's request. (Once a Year)
Mainten	due with	performed <b>twice</b> a ye n the yearly fee due a Maintenance Service	
Sales Rep	resentative		
Customer	Acceptance	Signature Date	

TERM: This is not a service contract. This is a preventative maintenance contract. The term of this agreement will be for a period of one (1) year or twelve consecutive months beginning on the first service date written above. This agreement will automatically renew on its anniversary date, unless either party shall notify the other in writing at least 30 days prior to that date. There will be no refunds if the yearly fee has been paid and the homeowner sells the home. If and when price adjustments would be necessary, a written notice at least 30 days prior to the effective date will be provided. No claim for damages due to termination under the above stated information should arise against either party. Please sign and fax/mail back to us to indicate your approval. Any additional material used for repairs will be charged to the generators owner at current rates. Emergency service, between scheduled inspections, will be provided Monday through Friday during the regular business hours of 7:00am and 3:30pm will be charged at our current labor rates plus travel time. Emergency service required Monday through Friday other than our regular business hours 7:00am and 3:30pm would be charged at our overtime rate. This includes any requests for service on Saturday, Sunday, and holidays. The customer or equipment owner shall hold O.J. Mann Electric Services, Inc. harmless from any or all liability resulting in physical damage, personal injury, or any other losses due to equipment or system failure and/or operation. REV: 3/11/22.

1484 Highland Avenue | Unit 4B Cheshire, Connectiut 06410 CT LIC# 103686 Phone: (203) 250-8715 Fax: (203) 250-8748

Website: www.ojmannelectric.com

# GENERATOR PREVENTATIVE MAINTENANCE CHECK-LIST (67 STEPS)

\*If you have a once a year contract everything is performed once a year

#### **IGNITION**

- ☑ Change all spark plugs as necessary (Once a Year)
- ☑ Check distributor cap and rotor
  - (Older liquid cooled generators only)
- ☑ Check start solenoid terminals
- ☑ Check all ignition wires
- ☑ Check and adjust choke when applicable

#### **ENGINE**

- ☑ Change oil (Twice a Year)
- ☑ Change oil filter (Twice a Year)
- ☑ Tighten valve covers
- ✓ Lubricate governor linkage (Mechanical governor only)
- ☑ Replace air filter (Twice a Year)
- ☑ Check entire unit for noticeable oil leaks

#### OIL ANALYSIS

#### (On customer requests and if oil looks poor)

- ☑ Sample oil and ship to independent third party for oil analysis
- ☑ Metals analysis
- ☑ Contaminants analysis
- ☑ Additives analysis
- ☑ Physical/chemical analysis
- ☑ Itemized report from third party- given to client

#### **COOLING SYSTEM**

- ☑ Test coolant protection
- ☑ Test coolant alkalinity
- ☑ Check water hoses both upper and lower (Twice a Year)
- ☑ Check bypass hoses (Twice a Year)
- ☑ Check fan belts (Twice a Year)
- ☑ Check engine block heater for operation (Twice a Year)
- ☑ Check anti-freeze solution

## **EXHAUST SYSTEM**

- ☑ Check flexible section for cracks or leaks (Twice a Year)
- ☑ Check exhaust flange gaskets (Twice a Year)
- Check exhaust muffler & drain when applicable (Twice a Year)

#### **FUEL SYSTEM**

- ☑ Change primary and secondary fuel filters (Diesel only)
- ☑ Check injector fuel lines (Diesel only) (Twice a Year)
- ☑ Check fuel connections and tighten (Twice a Year)
- ☑ Check fuel solenoid (Twice a Year)
- ☑ Check day tank float (Diesel only) (Twice a Year)
- ☑ Check regulator (Twice a Year)

#### **BATTERY**

- ☑ Load test battery (Twice a Year)
- ☑ Check battery voltage (Twice a Year)
- ☑ Clean battery cables (Twice a Year)
- ✓ Clean battery terminals on cables (Twice a Year)

### **BATTERY (Continued)**

- ☑ Clean battery posts & install new battery washers (Twice a Year)
- ☑ Check fluid level and fill if required (Twice a Year)
- ☑ Replace battery once every four years.
- ☑ Check charge rate on alternator or internal charge circuit (Twice a Year)
- ☑ Check alternator belt (Twice a Year)

Note: Life of a battery- any generator built from 2007 and older should be replaced every 3-4 years because of the type of battery charger that charges constantly. Generators from 2008 and newer should be replaced every 4-5 years because the battery chargers don't charge all the time.

#### STARTING SYSTEM

- ☑ Check starter motor solenoid terminal (Twice a Year)
- ☑ Check starter motor (Twice a Year)

#### **ELECTRICAL**

- ☑ Check exciter (Twice a Year)
- ☑ Check voltage regulator (Twice a Year)
- ☑ Check rectifiers (Twice a Year)
- ☑ Check brushes (Twice a Year)
- ☑ Clean slip rings, if necessary check wiring and terminal (If slip rings need cleaning there would be an additional charge) (Twice a Year)

# **OPERATIONAL CHECKS**

Start generator and conduct safely shutdown tests for the following:

- ✓ Low oil pressure (Twice a Year)
- ☑ High water temperature (Twice a Year)
- ✓ Over speed (Twice a Year))
- ☑ High temperature (Twice a Year)
- ☑ Check voltage output (Twice a Year)
- ☑ Check frequency (Hz.) (Twice a Year)
- ☑ Record hour meter reading when applicable (Twice a Year)
- ☑ Check unit for vibration and any unusual noise (Twice a Year)

#### **AUTOMATIC SWITCH**

(Customer would have to supply access to ATS.

If outside, with permission from customer to test ATS.)

- ☑ Inspect contactor assembly and connections (Twice a Year)
- Check exerciser clock and time setting (only GTS (Generac) (Asco)) – (Twice a Year)
- ✓ Check time delays (Twice a Year)
- ☑ Check battery charger for proper output (Twice a Year)
- ☑ Check selector switch (Twice a Year)
- ☑ Check voltage sensors for visual conditions (Twice a Year)
- ☑ Start and stop generator from transfer switch
  (Testing should be a functional test on the
  ATS at least once a year if possible on every visit)

#### **FINAL CHECK**

- Check the selector switch is in the automatic mode (Twice a Year)
- ☑ Start and stop generator using generator controls (Twice a Year)

#### **GENERAL INSPECTION OF SITE**

☑ Inspect site for any debris or obstructions, which could be a potential problem or may be hazardous to operation. (Twice a Year)